

CERTIFICATE OF COMPLIANCE

Certificate Number 20181029-E308146
Report Reference E308146-20110324
Issue Date 2018-OCTOBER-29

Issued to: KNICK ELEKTRONISCHE MESSGERATE GMBH & CO
KG
BEUCKESTRASSE 22
14163 BERLIN GERMANY

**This is to certify that
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN
HAZARDOUS LOCATIONS

Open-type Repeater Power Supplies Series IsoAmp PWR
Types A 20100 through A 20199 or B 10100 through B
10199, followed by F0, S or Z for use in Class I, Division 2,
Groups A, B, C and D Hazardous Locations.

Each catalog number may be followed by - (hyphen) and
additional letters and/or digits referring to non-electrical
properties such as language, delivery packing and
documentation.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/ISA 12.12.01 (Nonincendive Electrical Equipment for
Use in Class I and II, Division 2 and Class III, Divisions 1
and 2 Hazardous (Classified) Locations) and CAN/CSA
C22.2 No. 213-M1987 (Non-incendive Electrical Equipment
for Use in Class I, Division 2 Hazardous Locations)

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

